



**Wheat Belt Public Power District
Board of Directors**

POLICY

Subject: Attachments to Poles		Policy No. C-3
Original Issue Date: Unknown	Date of Last Review: 01-28-11	Page 1 of 1

Attachments to, or the posting of notices or flyers to District poles without first obtaining a contract, or joint use agreement with the District, or unless specific written approval from Wheat Belt is received, is not allowed. Tacks staples or nails in a pole (from flyers or posters) are a climbing hazard for District linemen.

Wheat Belt PPD will allow fences to be attached to its poles, but to a height of no more than four feet above ground level. Fence posts may not be set closer than eight feet to the power pole. This is necessary to prevent a post from becoming a safety hazard, should a lineman fall from the pole.

_____, President Date: _____