

# Wheat Belt Public Power District

## Board of Directors

# Policy



Policy: **T-3**

Title: **Line Interference/Harmonics**

Page **1** of **1**

Original Issue: **07-26-2013**

Last Review: **11-24-2025**

Last Revised: **10-24-2025**

---

**RESPONSIBLE DEPARTMENT:** Manager of Technologies

**ACCOUNTABLE:** CEO

Line noise is unwanted electrical or electromagnetic energy that degrades the quality of signals and data. Noise occurs in digital and analog systems, and can affect communications of all types. The sensitivity of electronic equipment necessitates that the line be protected from this interference both for the customer and Wheat Belt.

**The following is a direct quote: “FCC Title 47, CFR Section 15.5 General conditions of operation.”**

“(c) The operator of the radio frequency device shall be required to cease operating the device upon notification by a Commission representative that the device is causing harmful interference. Operation shall not resume until the condition causing the harmful interference has been corrected.”

Services must comply with IEEE Standard 519, Recommended Practices and Requirements for Harmonic Control in Electrical Power Systems.

Customers whose equipment does not meet FCC regulations and/or IEEE Standard 519 will be notified by Certified Mail. FCC's preference is that corrections are made without FCC involvement. It is law that interference/harmonic problems must be corrected. Wheat Belt will notify the customer of the interference and allow corrective measures to be implemented in a reasonable amount of time. If the interference isn't corrected in a reasonable amount of time, the customer will be notified that the service will be disconnected until such time the customer is able to remedy the problem.

---

President

Date